

Missouri Department of Natural Resources



PUBLIC NOTICE

APPLICATION FOR MISSOURI STATE OPERATING PERMIT

DATE: August 18, 2006

In accordance with the state Clean Water Law, Chapter 644, RSMo, Clean Water Commission regulation 10 CSR 20-6.010, and the federal Clean Water Act, the applicants listed herein have applied for authorization to either discharge to waters of the state or to operate a no-discharge wastewater treatment facility. The proposed permits for these operations are consistent with applicable water quality standards, effluent standards and/or treatment requirements or suitable timetables to meet these requirements (see 10 CSR 20-7.015 and 7.031). All permits will be issued for a period of five years, unless noted otherwise in the Public Notice for that discharge.

On the basis of preliminary staff review and the application of applicable standards and regulations, the Missouri Department of Natural Resources, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions. The proposed determinations are tentative pending public comment.

Persons wishing to comment on the proposed effluent limitations and/or determinations are invited to submit them in writing to the Department of Natural Resources, Southwest Regional Office, Water Pollution Unit, 2040 W. Woodland, Springfield, Missouri 65807, ATTN: Cynthia S. Davies, Regional Director. Please include the permit number in all comment letters.

Comments should be confined to the issues relating to the proposed action and permit(s) and the effect on water quality. The department may not consider as relevant comments or objections to a permit based on issues outside the authority of the Clean Water Commission, (see Curdt v. Mo. Clean Water Commission, 586 S.W.2d 58 Mo. App. 1979).

All comments must be postmarked by September 17, 2006 or received in our office by 5:00 p.m. on September 20, 2006. The requirement of a signed document makes it impossible to accept email comments for consideration at this time. Comments will be considered in the formulation of all final determinations regarding the applications. If response to this notice indicates significant public interest, a public meeting or hearing may be held after due notice for the purpose of receiving public comment on the proposed permit or determination. Public hearings and/or issuance of the permit will be conducted or processed according to 10 CSR 20-6.020.

Copies of all draft permits, comments, and other information including copies of applicable regulations are available for inspection and copying at the department's website, <http://www.dnr.mo.gov/env/wpp/wpcp-pn.htm> or at the Department of Natural Resources, Southwest Regional Office, Water Pollution Unit, 2040 W. Woodland, Springfield, Missouri 65807, between the hours of 8:00 a.m. and 5:00 p.m., Monday through Friday.

Public Notice Date: August 18, 2006


Permit Number: MO-0113034

Southwest Regional Office

FACILITY NAME AND ADDRESS	NAME AND ADDRESS OF OWNER
Forsyth WWTF 200 Progress Hills Drive Forsyth, MO 65653	City of Forsyth PO Box 545 Forsyth, MO 65653
RECEIVING STREAM & LEGAL DESCRIPTION	TYPE OF DISCHARGE
Bull Shoals Lake, NE ¼, SE ¼, SE ¼, Sec. 33, T24N, R20W, Taney County	Domestic, modification

Plans and specifications for this facility have, been reviewed by the Department of Natural Resources. The design engineer, a registered Missouri professional engineer, has certified that the plans and specifications meet all requirements of 10 CSR 20-Chapter 8 Waste Treatment Design.

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO-0113034

Owner: City of Forsyth
Address: PO Box 545, Forsyth, MO 65653

Continuing Authority: Same as above
Address: Same as above

Facility Name: Forsyth Wastewater Treatment Facility
Facility Address: 200 Progress Hills Drive, Forsyth, MO 65653

Legal Description: NE ¼, SE ¼, SE ¼, Sec. 33, T24N, R20W, Taney County

Receiving Stream: Unnamed Tributary to Bull Shoals Lake (U)
First Classified Stream and ID: Bull Shoals Lake (L2)(07315)
USGS Basin & Sub-watershed No.: (11010003-030004)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 - POTW - SIC #4952

Oxidation ditch/clarifiers/seasonal ultraviolet disinfection/sludge is land applied.

Design organic population equivalent is 3,874.
Design average daily flow is 780,000 gallons per day.
Design sludge production is 54.6 dry tons/year.

Outfall #002 - POTW - SIC #4952

Stormwater.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

Effective Date (Revised)

Doyle Childers, Director, Department of Natural Resources
Executive Secretary, Clean Water Commission

Expiration Date
MO 780-0041 (10-93)

Cynthia S. Davies, Regional Director, Southwest Regional Office

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS					PAGE NUMBER Page 2 of 4	
					PERMIT NUMBER MO-0113034	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective date or upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	GPD	*		*	once/month**	24 hr. total
Biochemical Oxygen Demand ₅ *****	mg/L	40		20	once/month**	****
Total Suspended Solids*****	mg/L	40		20	once/month**	****
pH – Units	SU	***		***	once/month**	grab
Fecal Coliform (Note 1)	#/100mL	1000		400 (Note 2)	once/month**	grab
Oil & Grease	mg/L	15		10	once/month**	grab
Ammonia as N	mg/L	8.6		4.3	once/month**	grab
<u>Outfall #002</u>						
Flow	GPD	*		*	once/during discharge event*****	24 hr. Estimate
Biochemical Oxygen Demand ₅	mg/L		45	45	once/during discharge event*****	grab
Total Suspended Solids	mg/L		45	45	once/during discharge event*****	grab
pH – Units	SU	*****	45	*****	once/during discharge event*****	grab
MONITORING REPORTS SHALL BE SUBMITTED _____; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
B. STANDARD CONDITIONS						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I, II & III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- * Monitoring requirement only.
- ** Reports shall be submitted by the 28th day of the month following the reporting period, e.g. Reporting period is the month of March (samples collected monthly), report due by April 28th.
- *** pH is measured in pH units and is not to be averaged. The pH for all facilities except lagoons is limited to the range of 6.0-9.0 pH units.
- **** A composite sample made up from a minimum of four grab samples collected within a 24-hour period with a minimum of two hours between each grab sample. A person may physically collect the four grab samples or a composite sampler may be set up to collect the four grab samples.

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

***** This facility is required to provide a 30-day average percent removal of at least 85%.

***** **All samples shall be collected from a discharge resulting from a precipitation event greater than 0.1 inches in magnitude and that occurs at least 72 hours from the previously measurable precipitation event. Sampling shall occur once per discharge event, please note that monitoring reports shall be submitted no later than the 28th day of the month following the monitoring period. If a precipitation event does not occur within the reporting period, report as no discharge.**

***** pH is measured in pH units and is not to be averaged. The pH is to be maintained at or above 6.0 pH units.

Note 1 - Final limitations and monitoring requirements for Fecal Coliform are applicable only during the recreational season from April 1 through October 31.

Note 2 - Monthly average limit for Fecal Coliform is expressed as a geometric mean. Geometric mean for
 $n \text{ samples} = [a_1 \times a_2 \times a_3 \dots \times a_n]^{1/n}$

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:

- (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
- (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
- (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

2. All outfalls must be clearly marked in the field.
3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.
4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;

C. SPECIAL CONDITIONS (continued)

- (4) The level established in Part A of the permit by the Director.
 - (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
5. Report as no-discharge when a discharge does not occur during the report period.
6. Water Quality Standards
 - (a) Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
 - (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (5) There shall be no significant human health hazard from incidental contact with the water;
 - (6) There shall be no acute toxicity to livestock or wildlife watering;
 - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.
7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities
 - (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
 - (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.
8. The permittee shall submit a report semi-annually with the Discharge Monitoring Reports (on January 28 and July 28) which addresses measures taken to locate and eliminate sources of inflow and infiltration into the City's collection system.



Missouri Department of Natural Resources
Southwest Regional Office
NPDES PERMITS AND ENGINEERING SECTION

Water Quality Review Sheet

Determination of Effluent Limits

Facility Information

FACILITY NAME: Forsyth Oxidation Ditch NPDES #: MO-0113034

FACILITY TYPE/DESCRIPTION: Oxidation ditch/clarifiers/seasonal ultraviolet disinfection/sludge is land applied.

EDU*: Ozarks White Drainage 8- DIGIT HUC: 11010003 COUNTY: Taney

* - Ecological Drainage Unit

LEGAL DESCRIPTION: NE ¼, SE ¼, SE ¼, Sec. 33, T24N, R20W UTM: x: 491096.1675
LATITUDE/LONGITUDE: y: 4059778.5623

WATER QUALITY HISTORY: No violations within the last 18 months (only 18 months checked)

OUTFALL	DESIGN FLOW (CFS)	TREATMENT LEVEL	RECEIVING WATERBODY	DISTANCE TO CLASSIFIED SEGMENT (MI)
001	1.21	Secondary	Bull Shoals Lake	0.78

Receiving Waterbody Information

WATERBODY NAME	CLASS	WBID	LOW-FLOW VALUES (CFS)			DESIGNATED USES**
			1Q10	7Q10	30Q10	
Bull Shoals Lake	L2	A	62.8	109	150	LWW, AQL, CDF, WBC, SCR

** Irrigation (IRR), Livestock & Wildlife Watering (LWW), Protection of Warm Water Aquatic Life and Human Health-Fish Consumption (AQL), Cool Water Fishery (CLF), Cold Water Fishery (CDF), Whole Body Contact Recreation (WBC), Secondary Contact Recreation (SCR), Drinking Water Supply (DWS), Industrial (IND)

COMMENTS: Addition of aerator for oxidation ditch and mechanical grinder of influent

Mixing Considerations

Mixing Zone (MZ): Not to exceed one-quarter (1/4) of the lake width at the discharge point or one hundred feet (100') from the discharge point, whichever is less. 10 CSR 20-7.031 (4) (A) 5. B. (IV) (a). Therefore, MZ = 4.19 ft³/sec.

Zone of Initial Dilution (ZID): MCWC Regulations 10 CSR20-7.031(4)(A)5.B.(IV)(b) states no initial zone of dilution is allowed. This means WWTF discharge at a minimum must meet acute water quality criteria for aquatic life protection-general cold water fishery at the end of pipe.

Permit Limits and Information

WASTELOAD
ALLOCATION
STUDY CONDUCTED (Y
OR N):

N

USE ATTAINABILITY
ANALYSIS CONDUCTED
(Y OR N):

N

WHOLE BODY
CONTACT
USE RETAINED (Y OR
N):

Y

OUTFALL #001

WET TEST (Y OR
N):

N

FREQUENC
Y:

FUTURE = 1/
PERMIT CYCLE

AEC: 100%

METHOD: SINGLE
DILUTION

$$\text{A.E.C. \%} = \left(\frac{\text{Design Flow} + \text{Zone of Initial Dilution}}{\text{Design Flow}} \right)^{-1} \times 100$$

PARAMETER	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MONITORING FREQUENCY
FLOW	MONITOR		MONITOR	monthly
BOD ₅ (MG/L)	40		20	monthly
TSS (MG/L)	40		20	monthly
PH (S.U.)	6-9		6-9	monthly
AMMONIA AS N (YEAR ROUND)	8.6		4.3	monthly
FECAL COLIFORM (COLONIES/100 mL)	1000		400	monthly
OIL AND GREASE (MG/L)	15		10	monthly

Please report the date, time, and location for each parameter sampled along with the average daily flow (actual flow measured or estimated, not design flow). All the parameters should be sampled on the same day and within no more than a 2-hour period. Dissolved oxygen (DO) measurements are to be taken during the period from one hour prior to sunrise to one and one-half hour after sunrise. If discharge is contingent to storm events, rainfall should be measured every time there is a discharge.

Receiving Water Monitoring Requirements

No receiving water monitoring requirements recommended at this time.

Derivation and Discussion of Limits

Wasteload allocations were calculated using water quality criteria or water quality model results and the dilution equation below:

$$C = \frac{(C_s \times Q_s) + (C_e \times Q_e)}{(Q_e + Q_s)} \quad (\text{EPA/505/2-90-001, Section 4.5.5})$$

Where C = downstream concentration

Cs = upstream concentration

Qs = upstream flow

Ce = effluent concentration

Qe = effluent flow

Biochemical Oxygen Demand (BOD₅) Lake limits apply – 20 mg/L monthly average (10CSR 20-7.015(3)(B)1). Daily limits calculated by $(20 \times 3.114) / 1.5524 = 40$ mg/L daily maximum.

Total Suspended Solids (TSS) Lake limits apply – 20 mg/L monthly average (10CSR 20-7.015(3)(B)1). Daily limits are calculated by $(20 \times 3.114) / 1.5524 = 40$ mg/L daily maximum. 10 CSR 20-7.015(3)(B)2).

pH pH shall be maintained in the range from six to nine (6-9) standard units (10 CSR 20-7.015(3)(B)2).

Ammonia as Nitrogen. Total Ammonia Nitrogen – Early Life Stages Present criteria apply [10 CSR 20-7.031(4)(B)7.C. & Table B.]
No. 9, Page 847

Fecal Coliform: According to 10 CSR 20-7.015(3)(B)3, discharges to lakes and reservoirs identified as whole body contact areas shall not contain more than a monthly geometric mean of four hundred (400) fecal coliform colonies per one hundred milliliters (100 ml) and a daily maximum of one thousand (1,000) fecal coliform colonies per one hundred milliliters (100 ml).

Oil & Grease. Conventional pollutant, effluent limitation for protection of aquatic life; 10 mg/L monthly average, 15 mg/L daily maximum.

Chronic wasteload allocations were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration) and stream volume of flow at the edge of the mixing zone (MZ). Acute wasteload allocations were determined using applicable water quality criteria (CMC: criteria maximum concentration) and stream volume of flow at the edge of the zone of initial dilution (ZID).

Water quality based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA's "Technical Support Document For Water Quality-based Toxics Control" (EPA/505/2-90-001).

Reviewer: Tina A. White

Date: August 11, 2006

Unit Chief: Gale Roberts

Monitoring and effluent limits contained within this document have been developed in accordance with EPA guidelines using the best available data and are believed to be consistent with Missouri's Water Quality Standards and Effluent Regulations. If additional water quality data are available that may affect the recommended monitoring and effluent limits, please forward these data to the author.